

**Ministry of the Environment,  
Conservation and Parks**

Drinking Water and Environmental  
Compliance Division  
733 Exeter Rd  
London ON N6E 1L3  
Tel (519) 873-5000  
Fax (519) 873-5020

**Ministère de l'Environnement, de la  
Protection de la nature et des Parcs**

Division de la conformité en matière d'eau  
potable et d'environnement  
733, rue Exeter  
London ON N6E 1L3  
Tel (519) 873-5000  
Fax (519) 873-5020



June 25, 2024

File no. SI-MI-TC-TH-540

The Corporation of the Municipality of Thames Centre  
4305 Hamilton Road  
Dorchester, ON, N0L 1G5

Attention: Kevin Willson, Environmental Services Superintendent

Re: Inspection Report - Thorndale Drinking Water System (WW #220006115)  
Inspection conducted on May 30, 2024

---

Dear Mr. Willson,

Enclosed is the 2024-25 inspection report for the Thorndale Drinking Water System, corresponding Inspection Rating Report (IRR) and Risk Methodology document.


Section 19 of the Safe Drinking Water Act (Standard of Care) creates obligations for individuals who exercise decision-making authority over municipal drinking water systems. Please be aware that the Ministry has encouraged such individuals, particularly municipal councillors, to take steps to be better informed about the drinking water system(s) over which they have decision-making authority. These steps could include asking for a copy of this inspection report and a review of its findings. Further information about Section 19 can be found in "Taking Care of Your Drinking Water: A Guide for Members of Municipal Councils" on the Drinking Water Ontario website at <https://www.ontario.ca/environment-and-energy/taking-care-your-drinking-water-guide-members-municipal-councils>.

The IRR is a summarized quantitative measure of the drinking water system's annual inspection and is published in the Ministry's Chief Drinking Water Inspector's Annual Report. The Risk Methodology document describes the risk rating methodology which has been applied to the findings of the Ministry's municipal residential drinking water system inspection results.

If you have any questions or concerns regarding the rating, please contact Mark Smith, Water Compliance Supervisor, at [Mark.Smith@ontario.ca](mailto:Mark.Smith@ontario.ca) or (226)873-5020.

I would be pleased to answer any questions or provide additional clarification regarding the report.

Yours truly,

  
Andrew Winkler  
Provincial Officer  
London District Office


cc. Middlesex London Health Unit  
Upper Thames River Conservation Area  
MECP London District File



THORNDALE DRINKING WATER SYSTEM  
Physical Address: 17163 THORNDALE RD, ,  
THAMES CENTRE, ON N0M 2P0

## INSPECTION REPORT

Entity: MUNICIPALITY OF THAMES  
CENTRE  
Inspection Start Date: May 30, 2024  
Site Inspection Date: May 30, 2024  
Inspection End Date: June 13, 2024  
Inspected By: Andrew Winkler  
Badge #: 1908



(signature)

## INTRODUCTION

### **Purpose**

This announced, focused inspection was conducted to confirm compliance with Ministry of the Environment, Conservation and Parks' (MECP) legislation and conformance with ministry drinking water policies and guidelines.

### **Scope**

The ministry utilizes a comprehensive, multi-barrier approach in the inspection of water systems that focuses on the source, treatment, and distribution components as well as management and the operation of the system.

The inspection of the drinking water system included both the physical inspection of the component parts of the system listed in section 4 "Systems Components" of the report and the review of data and documents associated with the operation of the drinking water system during the review period.

This drinking water system is subject to the legislative requirements of the Safe Drinking Water Act, 2002 (SDWA) and regulations made therein, including Ontario Regulation 170/03, "Drinking Water Systems" (O. Reg. 170/03). This inspection has been conducted pursuant to Section 81 of the SDWA.

This inspection report does not suggest that all applicable legislation and regulations were evaluated. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

### **Facility Contacts and Dates**

The drinking water system is owned by the Municipality of Thames Centre and operated the Municipality of Thames Centre. The system serves an estimated population of 1,803 and is categorized as a Large Municipal Residential System. Information reviewed for this inspection covered the time period of June 16, 2013 to May 30, 2024.

The ministry's Water Compliance Officer met with municipal staff as part of the inspection process.

### **Systems/Components**

All locations associated with primary disinfection were visited as part of this inspection. The following sites were visited as part of the inspection of the drinking water system:

- Thorndale drinking water facility, two production wells, and water tower.

### **Permissions/Approvals**

This drinking water system was subject to specific conditions contained within the following permissions and/or approvals (please note this list is not exhaustive) at the time of the inspection in addition to the requirements of the SDWA and its regulations:

- Municipal Drinking Water Licence (MDWL) #059-101, Issue #5, October 18, 2023.
- Drinking Water Works Permit (DWWP) # 059-201, Issue #6, Issue date: October 18, 2023.
- Permit to Take Water (PTTW) number 5082-AP2RUV, issued on July 27, 2017.

### **NON-COMPLIANCE**

The following item(s) have been identified as non-compliance, based on a "No" response captured for a legislative question(s). For additional information on each question see the Inspection Details section of the report.

**Ministry Program:** DRINKING WATER | **Regulated Activity:** DW Municipal Residential

Item	Question	Compliance Response/Corrective Action(s)
NC-1	<p><b>Question ID:</b> DWMR1025001</p> <p>Were all parts of the drinking water system that came in contact with drinking water disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit?</p>	<p>All parts of the drinking water system were not disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit.</p> <p><b>Requirements</b> Condition 2.3, Schedule B of the Drinking Water Works Permit (DWWP) requires all parts of the drinking water system that come into contact with drinking water, be disinfected in accordance with a procedure approved by the ministry's Director or in accordance with the applicable provisions identified in the DWWP.</p> <p><b>Observations</b> Disinfection records were provided for the following projects: - Watermain commissioning of Nissouri Road extension. - Watermain commissioning of Rosewood phase 2.</p> <p>The facility logbook includes an entry on September 6, 2023. That describes the installation of a sample collection line in the by-pass chamber/clearwell, down flow from the chlorine contact chamber. However, no disinfection records were available for this project.</p> <p><b>Corrective Actions</b> The system owner shall ensure that the American Water Works Association disinfection procedures are followed, and pertinent details are recorded.</p>

## **RECOMMENDATIONS**

This should not be construed as a confirmation of full conformance with all potential applicable BMPs. These inspection findings are limited to the components and/or activities that were assessed, and the legislative framework(s) that were applied. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

If you have any questions related to this inspection, please contact the signed Provincial Officer.

### INSPECTION DETAILS

This section includes all questions that were assessed during the inspection.

**Ministry Program:** DRINKING WATER | **Regulated Activity:** DW Municipal Residential

<b>Question ID</b>	DWMR1007001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   1-2   (1)1;			
<b>Question:</b> Was the owner maintaining the production well(s) in a manner sufficient to prevent entry into the well of surface water and other foreign materials?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> The owner was maintaining the production well(s) in a manner sufficient to prevent entry into the well of surface water and other foreign materials.  Well #1 is located inside the locked water treatment building. No concerns noted with respect to entry of surface water or other foreign materials.  Well #2 is located southeast of the water treatment building, inside the fenced compound. Complete with a commercially manufactured well cap with a screened vent and seals. The electrical conduit was securely fastened to the well cap. Land drainage in proximity to the well appeared sufficient to prevent pooling water or erosion. No immediate concerns noted with respect to sources of contaminants in proximity to the well.			

<b>Question ID</b>	DWMR1009001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Were measures in place to protect the groundwater and/or GUDI source in accordance with the Municipal Drinking Water Licence and Drinking Water Works Permit?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Measures were in place to protect the groundwater and/or GUDI source.  In accordance with the MDWL, the system owner created a well inspection schedule for the wells associated with the drinking water system. The well inspection and maintenance procedures considered above and below grade well components.  A double walled diesel fuel storage tank for the standby generator was installed at water treatment facility. Operators routinely visually inspect the fuel tank's integrity. In addition to the minimum conditions identified in the DWWP, the services of a certified fuel tank inspector is obtained to inspect the diesel fuel tank annually.			



<b>Question ID</b>	DWMR1014001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Was flow monitoring performed as required by the Municipal Drinking Water Licence or Drinking Water Works Permit?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Flow monitoring was performed as required.  Flow meters were installed to measure raw water taken from each of the two production wells, and one to measure the flow of treated water leaving the water treatment facility. Further, flow meters measure water flowing through the water tower.			

<b>Question ID</b>	DWMR1016001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Was the owner in compliance with the conditions associated with maximum flow rate or the rated/operational capacity in the Municipal Drinking Water Licence?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> The owner was in compliance with the conditions associated with maximum flow rate and/or the rated/operational capacity conditions.			

<b>Question ID</b>	DWMR1018001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Did the owner ensure that equipment was installed in accordance with Schedule A and Schedule C of the Drinking Water Works Permit?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> The owner ensured that equipment was installed as required.			

<b>Question ID</b>	DWMR1020001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			

<p><b>Question:</b> Were Form 1 documents prepared as required?</p>
<p><b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Form 1 documents were prepared as required.</p> <p>Records of watermains authorized as future alterations were provided for the following projects:</p> <ul style="list-style-type: none"> <li>- Watermain installation on Nissouri Road, south of Gerald Parkway.</li> <li>- Watermain installation for Rosewood Phase 2 Subdivision.</li> </ul>

<b>Question ID</b>	DWMR1021001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Were Form 2 documents prepared as required?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Form 2 documents were prepared as required.			
A Form 2 record was created for the new continuous analyzer and associated components, installed to monitor chlorine concentration in the by-pass chamber/clearwell.			

<b>Question ID</b>	DWMR1025001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Were all parts of the drinking water system that came in contact with drinking water disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> All parts of the drinking water system were not disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit.			
<p>Requirements</p> <p>Condition 2.3, Schedule B of the Drinking Water Works Permit (DWWP) requires all parts of the drinking water system that come into contact with drinking water, be disinfected in accordance with a procedure approved by the ministry's Director or in accordance with the applicable provisions identified in the DWWP.</p> <p>Observations</p> <p>Disinfection records were provided for the following projects:</p> <ul style="list-style-type: none"> <li>- Watermain commissioning of Nissouri Road extension.</li> <li>- Watermain commissioning of Rosewood phase 2.</li> </ul>			

The facility logbook includes an entry on September 6, 2023. That describes the installation of a sample collection line in the by-pass chamber/clearwell, down flow from the chlorine contact chamber. However, no disinfection records were available for this project.

**Corrective Actions**

The system owner shall ensure that the American Water Works Association disinfection procedures are followed, and pertinent details are recorded.

<b>Question ID</b>	DWMR1023001	<b>Question Type</b>	Legislative
<p><b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   1-2   (2);</p>			
<p><b>Question:</b> Did records indicate that the treatment equipment was operated in a manner that achieved the design capabilities prescribed by O. Reg. 170/03, Drinking Water Works Permit and/or Municipal Drinking Water Licence at all times that water was being supplied to consumers?</p>			
<p><b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Records indicated that the treatment equipment was operated in a manner that achieved the design capabilities prescribed.</p> <p>The system is designed to interchangeably take water from two groundwater wells. Sodium hypochlorite (liquid chlorine) is injected into raw water soon after entering the water treatment facility. Chlorinated water flows through the baffled chlorine contact chamber, and overflows a weir to the by-pass chamber/clearwell. The by-pass chamber/clearwell contains a single high lift pump (known as the fire pump) used in case of emergency. A submerged pipe connects the by-pass chamber/clearwell to a reservoir tank with two cells. High lift pumps in cell #1 push water to an off-site water tower. Then water flows to the first customer.</p> <p>Calculations provided demonstrate that CT for primary disinfection is achieved in the chlorine contact chamber. A continuous analyzer measures chlorine concentration in the by-pass chamber/clearwell, immediately after the chlorine contact chamber.</p> <p>According to the information provided, the following is a summary of critical parameters involved with two (2) operational scenarios.</p> <p>1) Scenario 1 – Well #1 in operation</p> <ul style="list-style-type: none"> <li>- Well pump #1 = 8.33 L/s</li> <li>- pH 6-9</li> <li>- Temperature = 5 °C</li> <li>- Cross section of contact chamber = 7.12 m<sup>2</sup></li> <li>- Minimum water depth in baffled contact chamber (to overflow weir) = 3.4 m</li> <li>- Baffling factor = 0.5</li> <li>- Minimum free chlorine residual = 0.165 mg/L</li> </ul>			

- 2) Scenario 2 – Well #2 in operation
- Well pump #2 = 22.0 L/s
  - pH 6-9
  - Temperature = 5 °C
  - Cross section of contact chamber = 7.12 m<sup>2</sup>
  - Minimum water depth in baffled contact chamber (to overflow weir) = 3.4 m
  - Baffling factor = 0.5
  - Minimum free chlorine residual = 0.436 mg/L

Data Review

Unusual SCADA data was attributed to analyzer calibration/maintenance, generator testing, & brief power outages, and not representative of water quality. The SCADA data provided for this inspection period demonstrates that primary disinfection was achieved while water was directed to the distribution system.

<b>Question ID</b>	DWMR1024001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   1-2   (2);			
<b>Question:</b> Did records confirm that the water treatment equipment which provides chlorination or chloramination for secondary disinfection was operated as required?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Records confirmed that the water treatment equipment which provides chlorination or chloramination for secondary disinfection was operated as required.			

<b>Question ID</b>	DWMR1033001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   7-2   (3); SDWA   O. Reg. 170/03   7-2   (4);			
<b>Question:</b> Was secondary disinfectant residual tested as required for the large municipal residential distribution system?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Secondary disinfectant residual was tested as required.			
Operators collect water samples from the distribution system and manually perform free chlorine residual tests daily. Test results are recorded on Thorndale Water Plant Daily Readings logsheets and chain of custody paperwork for microbiological samples.			

<b>Question ID</b>	DWMR1030001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   7-2   (1); SDWA   O. Reg. 170/03   7-2   (2);			
<b>Question:</b> Was primary disinfection chlorine monitoring being conducted at a location approved by Municipal Drinking Water Licence and/or Drinking Water Works Permit or at/near a location where the intended CT had just been achieved?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Primary disinfection chlorine monitoring was conducted as required.  CT calculations provided for this inspection demonstrate that CT for primary disinfection is achieved in the chlorine contact chamber. In 2023, a continuous chlorine analyzer was installed to monitor chlorine residuals in the by-pass chamber/clearwell, immediately after the chlorine contact chamber.  The system is equipped with a post-chlorination system that includes an additional chlorine injection point after the high lift pumps. The post-chlorination system is designed to increase chlorine residual before water leaves the water treatment plant, if needed. A continuous chlorine analyzer (know as the distribution analyzer) measures free chlorine residual after the post chlorination injection point, and before water leaves the water treatment plant. The system owner is cautioned about using the distribution analyzer for CT purposes. Since the post-chlorination system may impact chlorine residual readings.			

<b>Question ID</b>	DWMR1035001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   6-5   (1)1-4;			
<b>Question:</b> Were operators examining continuous monitoring test results and did they examine the results within 72 hours of the test?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Operators were examining continuous monitoring test results as required.  Operators review critical data trending for the previous day using SCADA. Operators manually record critical operational data on a "Thorndale Water Plant Daily Readings" log sheet.			

<b>Question ID</b>	DWMR1038001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   6-5   (1)1-4;			
<b>Question:</b> Was continuous monitoring equipment that was being utilized to fulfill O. Reg. 170/03 requirements performing tests for the parameters with at least the minimum frequency and			

recording data with the prescribed format?

**Compliance Response(s)/Corrective Action(s)/Observation(s):**

Continuous monitoring equipment that was being utilized to fulfill O. Reg. 170/03 requirements was performing tests for the parameters with at least the minimum frequency and recording data with the prescribed format.

SCADA data was provided in a one-minute frequency for this inspection period. Data provided for the continuous analyzers included minimum, maximum and average test results.

<b>Question ID</b>	DWMR1037001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   6-5   (1)5-10; SDWA   O. Reg. 170/03   6-5   (1.1);			
<b>Question:</b> Were all continuous monitoring equipment utilized for sampling and testing required by O. Reg. 170/03, or Municipal Drinking Water Licence or Drinking Water Works Permit or order, equipped with alarms or shut-off mechanisms that satisfied the standards described in Schedule 6?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> All required continuous monitoring equipment utilized for sampling and testing were equipped with alarms or shut-off mechanisms that satisfied the standards  Continuous analyzers used to monitor chlorine residuals at the water treatment plant were equipped with alarms. During the inspection, alarm setpoints included:  1) By-pass chamber/clearwell chlorine analyzer: - High High = 2.10 mg/L. - High = 2.00 mg/L. - Low = 0.90 mg/L. - Low Low = 0.70 mg/L. Anticipated future installation of automatic shut-off mechanism for high lift pumps and well pumps.  2) Distribution chlorine analyzer: - High High = 2.00 mg/L. - High = 1.80 mg/L. - Low = 1.00 mg/L. - Low Low = 0.80 mg/L. Equipped with automatic shut-off mechanism for high lift pumps.			

<b>Question ID</b>	DWMR1040001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   6-5   (1)1-4; SDWA   O. Reg. 170/03   6-5   (1)5-10;			
<b>Question:</b> Were all continuous analysers calibrated, maintained, and operated, in accordance with the			

manufacturer's instructions or the regulation?

**Compliance Response(s)/Corrective Action(s)/Observation(s):**

All continuous analysers were calibrated, maintained, and operated as required.

Records demonstrated that operators typically verified/calibrated online continuous chlorine analyzers against a portable device at least weekly. Operators verified the portable devices against calibration standards monthly. A third-party verified/calibrated portable devices, flow meters and tank level meters annually.

<b>Question ID</b>	DWMR1108001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   6-5   (1)5-10; SDWA   O. Reg. 170/03   6-5   (1.1);			
<b>Question:</b> Where continuous monitoring equipment used for the monitoring of free chlorine residual, total chlorine residual, combined chlorine residual or turbidity, required by O. Reg. 170/03, Municipal Drinking Water Licence, Drinking Water Works Permit, or order triggered an alarm or an automatic shut-off, did a qualified person respond as required and take appropriate actions?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> A qualified person responded as required and took appropriate actions.  Operators recorded pertinent information in the facility logbook. Summary information was also recorded on an "Alarm Log" sheet.			

<b>Question ID</b>	DWMR1099001	<b>Question Type</b>	Information
<b>Legislative Requirement(s):</b> Not Applicable			
<b>Question:</b> Do records show that water provided by the drinking water system met the Ontario Drinking Water Quality Standards?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Records showed that all water sample results met the Ontario Drinking Water Quality Standards.			

<b>Question ID</b>	DWMR1083001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   10-3;			

<p><b>Question:</b> Were treated microbiological sampling requirements prescribed by Schedule 10-3 of O. Reg. 170/03 for large municipal residential systems met?</p>
<p><b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Treated microbiological sampling requirements were met.</p>

<b>Question ID</b>	DWMR1081001	<b>Question Type</b>	Legislative
<p><b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   10-2   (1); SDWA   O. Reg. 170/03   10-2   (2); SDWA   O. Reg. 170/03   10-2   (3);</p>			
<p><b>Question:</b> Were distribution microbiological sampling requirements prescribed by Schedule 10-2 of O. Reg. 170/03 for large municipal residential systems met?</p>			
<p><b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Distribution microbiological sampling requirements were met.</p> <p>Section 10-2. of O. Reg. 170/03 required at least eight (8) distribution samples taken for a system that serves a population less than 100,000, plus an additional sample for every 1,000 people served by the system, monthly. With at least one (1) of the samples collected each week. Each sample shall be tested for E.coli and total coliforms. While 25% of required samples shall be tested for general bacteria expressed as Heterotrophic Plate Count (HPC).</p> <p>Information provided to the ministry by the system owner indicated a population of 1,803 was serviced by the drinking water system. For the purpose of this section, a minimum of nine distribution samples shall be taken monthly.</p>			

<b>Question ID</b>	DWMR1096001	<b>Question Type</b>	Legislative
<p><b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   6-3   (1);</p>			
<p><b>Question:</b> Did records confirm that chlorine residual tests were conducted at the same time and location as microbiological samples?</p>			
<p><b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Records confirmed that chlorine residual tests were conducted as required.</p> <p>Operators recorded free chlorine residual test results on Chain of Custody paperwork submitted to the lab along with microbiological samples.</p>			



<b>Question ID</b>	DWMMR1084001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-2;			
<b>Question:</b> Were inorganic parameter sampling requirements prescribed by Schedule 13-2 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Inorganic parameter sampling requirements were met.  Section 13-2 of O. Reg. 170/03 required at least one sample collected and tested for the inorganic parameters identified in Schedule 23 every 36 months.			

<b>Question ID</b>	DWMMR1085001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-4   (1); SDWA   O. Reg. 170/03   13-4   (2); SDWA   O. Reg. 170/03   13-4   (3);			
<b>Question:</b> Were organic parameter sampling requirements prescribed by Schedule 13-4 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Organic parameter sampling requirements were met.  Section 13-4 of O. Reg. 170/03 required at least one sample collected and tested for the organic parameters identified in Schedule 24 every 36 months.			

<b>Question ID</b>	DWMMR1086001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-6.1   (1); SDWA   O. Reg. 170/03   13-6.1   (2); SDWA   O. Reg. 170/03   13-6.1   (3); SDWA   O. Reg. 170/03   13-6.1   (4); SDWA   O. Reg. 170/03   13-6.1   (5); SDWA   O. Reg. 170/03   13-6.1   (6);			
<b>Question:</b> Were haloacetic acid sampling requirements prescribed by Schedule 13-6 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Haloacetic acid sampling requirements were met.  Section 13-6.1 (1) & (2) of O. Reg. 170/03 required at least one distribution sample collected from a point in the distribution system or plumbing connected to the drinking water system, that is likely to have an elevated potential for the formation of haloacetic acids. Sample(s) must be collected every three months or in each calendar quarter and tested for haloacetic acids.			

Question ID	DWMR1087001	Question Type	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-6   (1); SDWA   O. Reg. 170/03   13-6   (2); SDWA   O. Reg. 170/03   13-6   (3); SDWA   O. Reg. 170/03   13-6   (4); SDWA   O. Reg. 170/03   13-6   (5); SDWA   O. Reg. 170/03   13-6   (6);			
<b>Question:</b> Were trihalomethane sampling requirements prescribed by Schedule 13-6 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Trihalomethane sampling requirements were met.  Section 13-6 (1) & (2) of O. Reg. 170/03 required at least one distribution sample collected from a point in the distribution system or plumbing connected to the drinking water system, that is likely to have an elevated potential for the formation of trihalomethanes. Sample(s) must be collected every three months or in each calendar quarter and tested for trihalomethanes.			

Question ID	DWMR1088001	Question Type	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-7;			
<b>Question:</b> Were nitrate/nitrite sampling requirements prescribed by Schedule 13-7 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Nitrate/nitrite sampling requirements were met.  Section 13-7 of O. Reg. 170/03 required at least one sample taken every three (3) months and tested for nitrate and nitrite.			

Question ID	DWMR1089001	Question Type	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-8;			
<b>Question:</b> Were sodium sampling requirements prescribed by Schedule 13-8 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Sodium sampling requirements were met.  Section 13-8 of O. Reg. 170 required at least one sample taken every 60 months and tested for sodium.			

<b>Question ID</b>	DWMR1090001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   13-9;			
<b>Question:</b> Where fluoridation is not practiced, were fluoride sampling requirements prescribed by Schedule 13-9 of O. Reg. 170/03 met?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Fluoride sampling requirements were met.  Section 13-9 of O. Reg. 170 required at least one sample taken every 60 months and tested for fluoride.			

<b>Question ID</b>	DWMR1113001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   10.1   (3);			
<b>Question:</b> Were changes to the system registration information provided to the ministry within ten (10) days of the change?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Changes to the system registration information were provided as required.			

<b>Question ID</b>	DWMR1045001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			
<b>Question:</b> Did the owner update the document describing the distribution components within 12 months of completion of alterations to the system in accordance with the Drinking Water Works Permit?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> The owner had up-to-date documents describing the distribution components.  The system's process schematic was updated to include the continuous chlorine analyzer and associated piping added to the by-pass chamber/clearwell.			

<b>Question ID</b>	DWMR1060001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   31   (1);			

<p><b>Question:</b> Did the operations and maintenance manual(s) meet the requirements of the Municipal Drinking Water Licence?</p>
<p><b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> The operations and maintenance manual(s) met the requirements of the Municipal Drinking Water Licence.</p>

<b>Question ID</b>	DWMR1062001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   7-5;			
<b>Question:</b> Did records or other record keeping mechanisms confirm that operational testing not performed by continuous monitoring equipment was done by a certified operator, water quality analyst, or person who met the requirements of Schedule 7-5 of O. Reg. 170/03?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Records or other record keeping mechanisms confirmed that operational testing not performed by continuous monitoring equipment was done by a certified operator, water quality analyst, or person who met the requirements of Schedule 7-5 of O. Reg. 170/03.  Operators who performed operational testing were clearly identified in the facility's logbook and on operational logsheets.			

<b>Question ID</b>	DWMR1071001	<b>Question Type</b>	BMP
<b>Legislative Requirement(s):</b> Not Applicable			
<b>Question:</b> Did the owner provide security measures to protect components of the drinking water system?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> The owner provided security measures to protect components of the drinking water system.			

<b>Question ID</b>	DWMR1073001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 128/04   23   (1);			
<b>Question:</b> Was an overall responsible operator designated for all subsystems which comprise the drinking water system?			

**Compliance Response(s)/Corrective Action(s)/Observation(s):**

An overall responsible operator was designated for all subsystem.

The Overall Responsible Operator (ORO) and back-up ORO both held valid water operator certificates appropriate for this system.

<b>Question ID</b>	DWMR1074001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 128/04   25   (1);			
<b>Question:</b> Were operators-in-charge designated for all subsystems which comprise the drinking water system?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Operators-in-charge were designated for all subsystems.			

<b>Question ID</b>	DWMR1075001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 128/04   22;			
<b>Question:</b> Were all operators certified as required?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> All operators were certified as required.			

<b>Question ID</b>	DWMR1076001	<b>Question Type</b>	Legislative
<b>Legislative Requirement(s):</b> SDWA   O. Reg. 170/03   1-2   (2);			
<b>Question:</b> Were adjustments to the treatment equipment only made by certified operators?			
<b>Compliance Response(s)/Corrective Action(s)/Observation(s):</b> Adjustments to the treatment equipment were only made by certified operators.  Entries in facility logbooks demonstrate that only certified operators adjusted treatment equipment.			



---

**Key Reference and Guidance Material for Drinking Water Systems**

---

# Key Reference and Guidance Material for Municipal Residential Drinking Water Systems

Many useful materials are available to help you operate your drinking water system. Below is a list of key materials owners and operators of municipal residential drinking water systems frequently use.

To access these materials online click on their titles in the table below or use your web browser to search for their titles. Contact the Ministry if you need assistance or have questions at 1-866-793-2588 or [waterforms@ontario.ca](mailto:waterforms@ontario.ca).

For more information on Ontario's drinking water visit [www.ontario.ca/drinkingwater](http://www.ontario.ca/drinkingwater)



PUBLICATION TITLE	PUBLICATION NUMBER
<b>FORMS:</b> Drinking Water System Profile Information Laboratory Services Notification Adverse Test Result Notification	012-2149E 012-2148E 012-4444E
Taking Care of Your Drinking Water: A Guide for Members of Municipal Councils	Website
Procedure for Disinfection of Drinking Water in Ontario	Website
Strategies for Minimizing the Disinfection Products Trihalomethanes and Haloacetic Acids	Website
Filtration Processes Technical Bulletin	Website
Ultraviolet Disinfection Technical Bulletin	Website
Guide for Applying for Drinking Water Works Permit Amendments, & License Amendments	Website
Certification Guide for Operators and Water Quality Analysts	Website
Guide to Drinking Water Operator Training Requirements	9802E
Community Sampling and Testing for Lead: Standard and Reduced Sampling and Eligibility for Exemption	Website
Drinking Water System Contact List	7128E01
Ontario's Drinking Water Quality Management Standard - Pocket Guide	Website
Watermain Disinfection Procedure	Website
List of Licensed Laboratories	Website

# Principaux guides et documents de référence sur les réseaux résidentiels municipaux d'eau potable

De nombreux documents utiles peuvent vous aider à exploiter votre réseau d'eau potable. Vous trouverez ci-après une liste de documents que les propriétaires et exploitants de réseaux résidentiels municipaux d'eau potable utilisent fréquemment. Pour accéder à ces documents en ligne, cliquez sur leur titre dans le tableau ci-dessous ou faites une recherche à l'aide de votre navigateur Web. Communiquez avec le ministère au 1-866-793-2588, ou encore à [waterforms@ontario.ca](mailto:waterforms@ontario.ca) si vous avez des questions ou besoin d'aide.



Pour plus de renseignements sur l'eau potable en Ontario, consultez le site [www.ontario.ca/eaupotable](http://www.ontario.ca/eaupotable)

TITRE DE LA PUBLICATION	NUMÉRO DE PUBLICATION
Renseignements sur le profil du réseau d'eau potable	012-2149F
Avis de demande de services de laboratoire	012-2148F
Avis de résultats d'analyse insatisfaisants et de règlement des problèmes	012-4444F
Prendre soin de votre eau potable - Un guide destiné aux membres des conseils municipaux	Site Web
Marche à suivre pour désinfecter l'eau potable en Ontario	Site Web
Stratégies pour minimiser les trihalométhanes et les acides haloacétiques de sous-produits de désinfection	Site Web
Filtration Processes Technical Bulletin (en anglais seulement)	Site Web
Ultraviolet Disinfection Technical Bulletin (en anglais seulement)	Site Web
Guide de présentation d'une demande de modification du permis d'aménagement de station de production d'eau potable	Site Web
Guide sur l'accréditation des exploitants de réseaux d'eau potable et des analystes de la qualité de l'eau de réseaux d'eau potable	Site Web
Guide sur les exigences relatives à la formation des exploitants de réseaux d'eau potable	9802F
Échantillonnage et analyse du plomb dans les collectivités : échantillonnage normalisé ou réduit et admissibilité à l'exemption	Site Web
Liste des personnes-ressources du réseau d'eau potable	Site Web
L'eau potable en Ontario - Norme de gestion de la qualité - Guide de poche	Site Web
Procédure de désinfection des conduites principales	Site Web
Laboratoires autorisés	Site Web



**Ontario**



**Ministry of the Environment, Conservation and Parks  
Drinking Water System Inspection Report  
Appendix B**

---

**Risk Methodology and Inspection Summary Rating Record**

---

# APPLICATION OF THE RISK METHODOLOGY USED FOR MEASURING MUNICIPAL RESIDENTIAL DRINKING WATER SYSTEM INSPECTION RESULTS



The Ministry of the Environment (MOE) has a rigorous and comprehensive inspection program for municipal residential drinking water systems (MRDWS). Its objective is to determine the compliance of MRDWS with requirements under the Safe Drinking Water Act and associated regulations. It is the responsibility of the municipal residential drinking water system owner to ensure their drinking water systems are in compliance with all applicable legal requirements.

This document describes the risk rating methodology, which has been applied to the findings of the Ministry's MRDWS inspection

results since fiscal year 2008-09. The primary goals of this assessment are to encourage ongoing improvement of these systems and to establish a way to measure this progress.

MOE reviews the risk rating methodology every three years.

The Ministry's Municipal Residential Drinking Water Inspection Protocol contains 15 inspection modules consisting of approximately 100 regulatory questions. Those protocol questions are also linked to definitive guidance that ministry inspectors use when conducting MRDWS inspections.

[ontario.ca/drinkingwater](http://ontario.ca/drinkingwater)

The questions address a wide range of regulatory issues, from administrative procedures to drinking water quality monitoring. The inspection protocol also contains a number of non-regulatory questions.

A team of drinking water specialists in the ministry assessed each of the inspection protocol regulatory questions to determine the risk (not complying with the regulation) to the delivery of safe drinking water. This assessment was based on established provincial risk assessment principles, with each question receiving a risk rating referred to as the Question Risk Rating. Based on the number of areas where a system is deemed to be non-compliant during the inspection, and the significance of these areas to administrative, environmental, and health consequences, a risk-based inspection rating is calculated by the ministry for each drinking water system.

It is important to be aware that an inspection rating less than 100 per cent does not mean the drinking water from the system is unsafe. It shows areas where a system’s operation can improve. The ministry works with owners and operators of systems to make sure they know what they need to do to achieve full compliance.

The inspection rating reflects the inspection results of the specific drinking water system for the reporting year. Since the methodology is applied consistently over a period of years, it serves as a comparative measure both provincially and in relation to the individual system. Both the drinking water system and the public are able to track the performance over time, which encourages continuous improvement and allows systems to identify specific areas requiring attention.

The ministry’s annual inspection program is an important aspect of our drinking water safety net. The ministry and its partners share a common commitment to excellence and we continue to work toward the goal of 100 per cent regulatory compliance.

## Determining Potential to Compromise the Delivery of Safe Water

The risk management approach used for MRDWS is aligned with the Government of Ontario’s Risk Management Framework. Risk management is a systematic approach to identifying potential hazards, understanding the likelihood and consequences of the hazards, and taking steps to reduce their risk if necessary and as appropriate.

The Risk Management Framework provides a formula to be used in the determination of risk:

$$\text{RISK} = \text{LIKELIHOOD} \times \text{CONSEQUENCE}$$

(of the consequence)

Every regulatory question in the inspection protocol possesses a likelihood value (L) for an assigned consequence value (C) as described in **Table 1** and **Table 2**.

TABLE 1:	
Likelihood of Consequence Occurring	Likelihood Value
0% - 0.99% (Possible but Highly Unlikely)	L = 0
1 – 10% (Unlikely)	L = 1
11 – 49% (Possible)	L = 2
50 – 89% (Likely)	L = 3
90 – 100% (Almost Certain)	L = 4

TABLE 2:	
Consequence	Consequence Value
Medium Administrative Consequence	C = 1
Major Administrative Consequence	C = 2
Minor Environmental Consequence	C = 3
Minor Health Consequence	C = 4
Medium Environmental Consequence	C = 5
Major Environmental Consequence	C = 6
Medium Health Consequence	C = 7
Major Health Consequence	C = 8

The consequence values (0 through 8) are selected to align with other risk-based programs and projects currently under development or in use within the ministry as outlined in **Table 2**.

The Question Risk Rating for each regulatory inspection question is derived from an evaluation of every identified consequence and its corresponding likelihood of occurrence:

- All levels of consequence are evaluated for their potential to occur
- Greatest of all the combinations is selected.

The Question Risk Rating quantifies the risk of non-compliance of each question relative to the others. Questions with higher values are those with a potentially more significant impact on drinking water safety and a higher likelihood of occurrence. The highest possible value would be 32 (4×8) and the lowest would be 0 (0×1).

**Table 3** presents a sample question showing the risk rating determination process.

TABLE 3:							
Does the Operator in Charge ensure that the equipment and processes are monitored, inspected and evaluated?							
Risk = Likelihood × Consequence							
C=1	C=2	C=3	C=4	C=5	C=6	C=7	C=8
<b>Medium</b> Administrative Consequence	<b>Major</b> Administrative Consequence	<b>Minor</b> Environmental Consequence	<b>Minor</b> Health Consequence	<b>Medium</b> Environmental Consequence	<b>Major</b> Environmental Consequence	<b>Medium</b> Health Consequence	<b>Major</b> Health Consequence
L=4 (Almost Certain)	L=1 (Unlikely)	L=2 (Possible)	L=3 (Likely)	L=3 (Likely)	L=1 (Unlikely)	L=3 (Likely)	L=2 (Possible)
<b>R=4</b>	<b>R=2</b>	<b>R=6</b>	<b>R=12</b>	<b>R=15</b>	<b>R=6</b>	<b>R=21</b>	<b>R=16</b>

## Application of the Methodology to Inspection Results

Based on the results of a MRDWS inspection, an overall inspection risk rating is calculated. During an inspection, inspectors answer the questions related to regulatory compliance and input their “yes”, “no” or “not applicable” responses into the Ministry’s Laboratory and Waterworks Inspection System (LWIS) database. A “no” response indicates non-compliance. The maximum number of regulatory questions asked by an inspector varies by: system (i.e., distribution, stand-alone); type of inspection (i.e., focused, detailed); and source type (i.e., groundwater, surface water).


The risk ratings of all non-compliant answers are summed and divided by the sum of the risk ratings of all questions asked (maximum question rating). The resulting inspection risk rating (as a percentage) is subtracted from 100 per cent to arrive at the final inspection rating.

## Application of the Methodology for Public Reporting

The individual MRDWS Total Inspection Ratings are published with the ministry's Chief Drinking Water Inspector's Annual Report.

**Figure 1** presents the distribution of MRDWS ratings for a sample of annual inspections. Individual drinking water systems can compare against all the other inspected facilities over a period of inspection years.

**Figure 1: Year Over Year Distribution of MRDWS Ratings**



## Reporting Results to MRDWS Owners/Operators

A summary of inspection findings for each system is generated in the form of an Inspection Rating Record (IRR). The findings are grouped into the 15 possible modules of the inspection protocol,

which would provide the system owner/operator with information on the areas where they need to improve. The 15 modules are:

- |                         |                                 |  |  |
|-------------------------|---------------------------------|--|--|
| 1. Source               | 5. Treatment Process Monitoring | 9. Logbooks                            | 13. Water Quality Monitoring                       |
| 2. Permit to Take Water | 6. Process Wastewater           | 10. Contingency and Emergency Planning | 14. Reporting, Notification and Corrective Actions |
| 3. Capacity Assessment  | 7. Distribution System          | 11. Consumer Relations                 | 15. Other Inspection Findings                      |
| 4. Treatment Processes  | 8. Operations Manuals           | 12. Certification and Training         |  |

For further information, please visit [www.ontario.ca/drinkingwater](http://www.ontario.ca/drinkingwater)

Ministry of the Environment, Conservation and Parks - Inspection Summary Rating Record (Reporting Year - 2024-25)

<b>DWS Name:</b>	THORNDALE DRINKING WATER SYSTEM
<b>DWS Number:</b>	220006115
<b>DWS Owner:</b>	MUNICIPALITY OF THAMES CENTRE
<b>Municipal Location:</b>	THAMES CENTRE
<b>Regulation:</b>	O.REG. 170/03
<b>DWS Category:</b>	DW Municipal Residential
<b>Type of Inspection:</b>	Focused
<b>Compliance Assessment Start Date:</b>	May-30-2024
<b>Ministry Office:</b>	London District Office

**Maximum Risk Rating:** 452

Inspection Module	Non Compliance Risk (X out of Y)
Capacity Assessment	0/30
Certification and Training	0/42
Distribution System	0/4
Logbooks	0/14
Operations Manuals	0/14
Reporting & Corrective Actions	0/25
Source	0/14
Treatment Processes	21/197
Water Quality Monitoring	0/112
<b>Overall - Calculated</b>	<b>21/452</b>

**Inspection Risk Rating:** 4.65%

**Final Inspection Rating:** 95.35%

Ministry of the Environment, Conservation and Parks - Detailed Inspection Rating Record (Reporting Year - 2024-25)

**DWS Name:** THORNDALE DRINKING WATER SYSTEM  
**DWS Number:** 220006115  
**DWS Owner Name:** MUNICIPALITY OF THAMES CENTRE  
**Municipal Location:** THAMES CENTRE

**Regulation:** O.REG. 170/03  
**DWS Category:** DW Municipal Residential  
**Type of Inspection:** Focused  
**Compliance Assessment Start Date:** May-30-2024  
**Ministry Office:** London District Office

Non-Compliance Question(s)	Non Compliance Risk
<b>Treatment Processes</b>	
Were all parts of the drinking water system that came in contact with drinking water disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit?	21
<b>Overall - Total</b>	<b>21</b>

Maximum Question Rating: 452

**Inspection Risk Rating: 4.65%**

**FINAL INSPECTION RATING: 95.35%**